



GOVERNMENT OF ASSAM
INSPECTORATE OF ELECTRICITY
OFFICE OF THE CHIEF ELECTRICAL INSPECTOR-CUM-ADVISER:
1st FLOOR, WEST END BLOCK, HOUSEFED COMPLEX, BASISTHA ROAD:
DISPUR, GUWAHATI-781 006, ASSAM.

No. CEIA/TES-7879/ 2015/25

Dated Guwahati, the 14th May 2015.

From : Sri U. Gogoi,
Senior Electrical Inspector,
Govt. of Assam.

To ✓ The Manager,
Garbhanga Electrical Sub-Division,
APDCL (LAR), Beltala Guwahati-29.

Subject: Approval for energizing of voltage exceeding 650 Volts installation as required under regulation 43 of the Central Electricity Authority (measures related to safety and Electric Supply) Regulations, 2010 (*hereinafter referred as the "Regulations"*).

Reference: 1. Your letter vide No.APDCL (LAR)/GESD/T-166/2014-2015/2261 dated . 30 04.15.
2. Inspection of the installation on 08.05. 2015 by this inspectorate.

Sir,

Reference above, approval is hereby accorded for energizing of the following installation(s) as required under regulation 43 of the Central Electricity Authority (measures relating to safety and Electric Supply) Regulations, 2010. This approval is subject to the condition that all precautionary measures as laid down under the Electricity Act, 2003 and the C.E.A. Regulations 2010 made there under in force from time to time are strictly followed to ensure safety (within meaning of the Electricity Act & Regulations):

1. **11/0.4KV 1X 100 KVA** platform mounted outdoor Sub-Station (Transformer Serial No. 09-14/179/1, Make-Prag electricals Pvt. Ltd.) & 11KV Overhead line of length 10 meter & XLPE underground cable of length 55 meter installed for power supply to Institute of Community Ophthalmology, C/o Sri Kanchi Sankar Health & Educational Foundation(Regd.) Beltola, Guwahati-29.

Conditions to be complied with by the supplier/owner/consumer/occupier of the electrical installation at the aforesaid premises;

1. The Sub-Station and main control panel to be protected from physical interference by adopting appropriate measures.
2. Cable marker to be provided on the cable routes/ trench for identification of trenches.
3. Arcing horns to be installed at the HT bushing of the transformer.
4. It shall be the responsibility of the owner of the above mentioned high voltage installation to maintain and operate the installation in a condition free from danger and as recommended by the manufacturer and/or by the relevant Codes of practice of the Bureau of Indian Standard and/or by an Electrical Inspector.

Receipt of Treasury Challan for ₹ 855.00 (Rupees Eight Hundred Fifty Five) only is hereby acknowledged with thanks.


Please note that this approval is accorded subject to strict compliance of the conditions laid down in the foregoing paras, violation of which may also attract penal provisions under the Act/Regulations in addition to revocation of this approval

Receipt of this approval letter may please be acknowledged.

N.B: As provided under the Regulations, any act of replacement/augmentation/adjustment etc. resulting to addition or alteration in the capacity or character and/or size of the installation(s) i writing from the undersigned including transformer shall necessitate due and prior approval in writing from the undersigned.

[Conserve Energy for Benefit of Self and Nation]

Yours faithfully,


Senior Electrical Inspector,
Government of Assam.

GOVERNMENT OF ASSAM
INSPECTORATE OF ELECTRICITY
OFFICE OF THE CHIEF ELECTRICAL INSPECTOR-CUM-ADVISER, ASSAM,
MAHABHAIRAB BUILDING: PUB-SARANIA ROAD: GUWAHATI-781003:

No. CEIA/TES-6744/2012/38

Dated Guwahati, the 8th August 2012.

From : Sri U. Konwar,
Senior Electrical Inspector, Govt. of Assam.

To : The Manager,
Garbhanga Electrical Sub-Division,
APDCL (LAZ), Beltola, Guwahati-28.

Subject: Approval for energizing of voltage exceeding 650 Volts installation as required under regulation 43 of the Central Electricity Authority (measures related to safety and Electric Supply) Regulations, 2010 (*hereinafter referred as the "Regulations"*).

Reference: 1. Your letter vide No. APDCL (LAZ)/GESD/T-193/2011-2012/3032, dated 2nd August 2012.
2. Inspection of the installation on 4th August 2012 by this Inspectorate.

Sir,
Reference above, approval/~~provisional approval~~ is hereby accorded for energizing of the following installation(s) as required under regulation 43 of the Central Electricity Authority (measures relating to safety and Electric Supply) Regulations, 2010. This approval is subject to the condition that all precautionary measures as laid down under the Electricity Act, 2003 and the C.E.A. Regulations 2010 made there under in force from time to time are strictly followed to ensure safety (within meaning of the Electricity Act & Regulations):

1. **11/0.4KV 1X630 KVA** pad mounted outdoor Sub-Station (Transformer Serial No. PM-630/03, Make-Power Maker) & 11KV overhead line of length 0.020 kilometers installed for power supply to **Sankardeva Nethralaya** at Beltola, Guwahati-28.

Item(s) to be complied with prior to the energisation of the electrical installation(s);

1. Distance from one earth pit to another to be properly and visibly maintained for testing/inspection for all the times.

Receipt of Treasury Challan No. 6/5691, dated 15th June 2012 of Dispur Treasury for ₹1,250.00 (Rupees One Thousand Two Hundred Fifty) only is hereby acknowledged with thanks.

Please note that this approval is accorded subject to strict compliance of the conditions laid down in the foregoing paras, violation of which may also attract penal provisions under the Act/Regulations in addition to revocation of this approval.

Receipt of this approval letter may please be acknowledged.

N.B: *As provided under the Regulations, any act of replacement/augmentation/adjustment etc. resulting to addition or alteration in the capacity or character and/or size of the installation(s) including transformer shall necessitate due and prior approval in writing from the undersigned.*

Yours faithfully,


8/8/12

Senior Electrical Inspector,
Government of Assam.

[Conserve Energy for Benefit of Self and Nation]