



GOVERNMENT OF ASSAM  
INSPECTORATE OF ELECTRICITY  
OFFICE OF THE CHIEF ELECTRICAL INSPECTOR-CUM-ADVISER,  
1<sup>ST</sup> FLOOR, WEST END BLOCK, HOUSEFED COMPLEX, DISPUR, GUWAHATI-781 006.  
\*\*\*\*

No. CEIA/TES-6184/2016/362

Dated Guwahati, the 10<sup>th</sup> March 2016.

From : Sri U. Gogoi,  
Senior Electrical Inspector,  
Govt. of Assam.

To : ✓ The Medical Director,  
Sri Sankardeva Netralaya,  
96, Basistha Road, Beltola, Guwahati-29, Assam.

Sub : Application under regulation 32 of the Central Electricity Authority (measures relating to safety and Electric Supply ) Regulations, 2010 (*hereinafter referred* as the "Regulations" ) for commissioning generating units in the premises of Sri Sankardeva Netralaya, 96, Basistha Road, Beltola, Guwahati-29, Assam.

Ref : Your letter vide No: SSN/ICO/DG/50(KVA)/2015-16, Dtd. 16.11.15

Sir,

With reference to the above mentioned application(s) under regulation 32 of the Regulations, this is to inform you that you may proceed with commissioning the following electric generating set(s) subject to due compliance of all the safety precautionary measures as laid down in the Regulations referred to the above at all time :

Sl No	Capacity (KW/KVA)	Rated Voltage	Make & Sl. No.		
			Alternator No.	Engine No.	Make
1.	500 KVA	415 Volt	Stamford N12E2060900	Cumins 25378815	Cummins India Ltd.

No change in the installations from the approved drawing may be made to the effect of changing the installation in character and/ or size without prior clearance from this end.

Use of changeover/ interlocking arrangement to prevent possibility of inadvertent or accidental paralleling of the generator(s) with supplier's system shall be strictly adhered to as indicated in the approved drawing(s) and the installation shall be linked to the supplier's system through the change over switch only after the supplier is satisfied that the installation is not likely to constitute any danger.

The owner/ user of the D.G. set(s) shall be responsible to maintain and operating the electrical installation including the D.G. Set(s) in the aforesaid premises in a condition free from danger, engaging competent and designated personnel having requisite Electrical Workmen Permit or Electrical Supervisory Certificate of Competency.

The following special precaution need also be taken when using generator for standby/emergency power supply.

- (1) Only four pole and two poles change over switches be used in a three phase and Single phase circuits respectively.
- (2) The generator wiring must be drawn separately from the main distribution system and as far as practicable drawn in separate ducts.

P.T.O

(2)

Receipt of Treasury Challan No. 05/01230, dtd. 07.05.15 for ₹ 750.00 (Rupees Seven Hundred Fifty) only of Dispur Treasury is hereby acknowledged with thanks.

Yours faithfully




Senior Electrical Inspector,  
Government of Assam.

Memo No. CEIA/TES-6184/2016/362-A

Dated Guwahati, the 10<sup>th</sup> March 2016.

1. The Superintendent of Taxes, Guwahati, Assam for favour of information.



Senior Electrical Inspector,  
Government of Assam.